



TOWN OF ROSS
RESIDENTIAL AND NON-RESIDENTIAL
CHECKLIST FOR PERMITTING ELECTRIC VEHICLES
AND ELECTRIC VEHICLE SERVICE EQUIPMENT (EVSE)

Please complete the following information related to permitting and installation of Electric Vehicle Service Equipment (EVSE) as a supplement to the application for a building permit. This checklist contains the technical aspects of EVSE installations and is intended to help expedite permitting and use for electric vehicle charging.

Upon this checklist being deemed complete, a permit shall be issued to the applicant. However, if it is determined that the installation might have a specific adverse impact on public health or safety, additional verification will be required before a permit can be issued.

This checklist substantially follows the *"Plug-In Electric Vehicle Infrastructure Permitting Checklist"* contained in the *Governor's Office of Planning and Research "Zero Emission Vehicles in California: Community Readiness Guidebook"* and is purposed to augment the guidebook's checklist.

Job Address:	Permit No.
<input type="checkbox"/> Single-Family <input type="checkbox"/> Multi-Family (Apartment) <input type="checkbox"/> Multi-Family (Condominium) <input type="checkbox"/> Commercial (Single Business) <input type="checkbox"/> Commercial (Multi-Businesses) <input type="checkbox"/> Mixed-Use <input type="checkbox"/> Public Right-of-Way	
Location and Number of EVSE to be Installed:	
Garage _____ Parking Level(s) _____ Parking Lot _____ Street Curb _____	
Description of Work:	

Applicant Name:	
Applicant Phone & email:	
Contractor Name:	License Number & Type:
Contractor Phone & email:	
Owner Name:	
Owner Phone & email:	

EVSE Charging Level: ___ Level 1 (120V) ___ Level 2 (240V) ___ Level 3(480V)	
Maximum Rating (Nameplate) of EV Service Equipment = _____ kW	
Voltage EVSE = _____ V	Manufacturer of EVSE: _____
Mounting of EVSE: ___ Wall Mount ___ Pole Pedestal Mount ___ Other _____	

System Voltage: ___ 120/240V, 1 ϕ , 3W ___ 120/208V, 3 ϕ , 4W ___ 120/240V, 3 ϕ , 4W ___ 277/480V, 3 ϕ , 4W ___ Other _____
Rating of Existing Main Electrical Service Equipment = _____ Amperes
Rating of Panel Supplying EVSE (if not directly from Main Service) = _____ Amps
Rating of Circuit for EVSE: _____ Amps / _____ Poles
AIC Rating of EVSE Circuit Breaker (if not Single Family, 400A) = _____ A.I.C. <i>(or verify with Inspector in field)</i>

Specify Either Connected, Calculated or Documented Demand Load of Existing Panel:
<ul style="list-style-type: none"> • Connected Load of Existing Panel Supplying EVSE = _____ Amps

<ul style="list-style-type: none"> • Calculated Load of Existing Panel Supplying EVSE = _____ Amps
<ul style="list-style-type: none"> • Demand Load of Existing Panel or Service Supplying EVSE = _____ Amps <i>(Provide Demand Load Reading from Electric Utility)</i>
<p>Total Load (Existing plus EVSE Load) = _____ Amps</p>
<p>For Single Family Dwellings, if the Existing Load is not known by any of the above methods, consistent with the "Single-Family Residential Permitting Application Example" in the Governor's Office of Planning and Research "Zero Emission Vehicles in California: Community Readiness Guidebook", please complete the attached "Plug-In Electric Vehicle Load Calculator for Level 2 Charging".</p>

<p>EVSE Rating _____ Amps x 1.25 = _____ Amps = Minimum Ampacity of EVSE Conductor = # _____ AWG</p>
<p>For Single-Family: Size of Existing Service Conductors = # _____ AWG or kcmil - or - : Size of Existing Feeder Conductor Supplying EVSE Panel = # _____ AWG or kcmil <i>(or Verify with Inspector in field)</i></p>

I hereby acknowledge that the information presented is a true and correct representation of existing conditions at the job site and that any causes for concern as to life-safety verifications may require further substantiation of information.

Signature of Permit Applicant: _____ Date: _____

Plug-In Electric Vehicle Load Calculator for Level 2 Charging

INSTRUCTIONS: Review the list of electrical loads in the table below and check all that exist in your home (don't forget to include the proposed Level 2 charger). For each item checked, fill in the corresponding "Watts Used" (refer to the "Typical Usage" column for wattage information). Add up all of the numbers that are written in the "Watts Used" column and write that number in the "TOTAL WATTS USED" box at the bottom of the table, then go to the next page to determine if your existing electric service will accommodate the new loads.

(Loads shown are rough estimates; actual loads may vary. For a more precise analysis, use the nameplate ratings for appliances and other loads and consult with a trained electrical professional.)

Check all Applicable Loads (✓)	Description of Load	Typical Usage	Watts Used
GENERAL LIGHTING AND RECEPTACLE OUTLET CIRCUITS			
<input type="checkbox"/>	Multiply the square footage of house x 3	3 watts/sq. ft.	
KITCHEN CIRCUITS			
<input type="checkbox"/>	Kitchen circuits	3,000 watts	
<input type="checkbox"/>	Electric oven	2,000 watts	
<input type="checkbox"/>	Electric stove top	5,000 watts	
<input type="checkbox"/>	Microwave	1,500 watts	
<input type="checkbox"/>	Garbage disposal under kitchen sink	1,000 watts	
<input type="checkbox"/>	Automatic dish washer	3,500 watts	
<input type="checkbox"/>	Garbage compactor	1,000 watts	
<input type="checkbox"/>	Instantaneous hot water at sink	1,500 watts	
LAUNDRY CIRCUIT			
<input type="checkbox"/>	Laundry circuit	1,500 watts	
<input type="checkbox"/>	Electric clothes dryer	4,500 watts	
HEATING AND AIR CONDITIONING CIRCUITS			
<input type="checkbox"/>	Central heating and air conditioning	6,000 watts	
<input type="checkbox"/>	Window mounted air conditioning	1,000 watts	
<input type="checkbox"/>	Whole-house or attic fan	500 watts	
<input type="checkbox"/>	Central electric furnace	8,000 watts	
<input type="checkbox"/>	Evaporative cooler	500 watts	
OTHER ELECTRICAL LOADS			
<input type="checkbox"/>	Electric water heater (storage type)	4,000 watts	
<input type="checkbox"/>	Electric tankless water heater	15,000 watts	
<input type="checkbox"/>	Swimming pool or spa	3,500 watts	
<input type="checkbox"/>			
<input type="checkbox"/>			
ELECTRIC VEHICLE CHARGER CIRCUIT			
	Level 2 electric vehicle charger wattage rating		
TOTAL WATTS USED			0

INSTRUCTIONS: Using the "TOTAL WATTS USED" number from the previous page, check the appropriate line in column 1 and follow that line across to determine the minimum required size of the electrical service panel shown in column 3. In column 4, write in the size of your existing service panel (main breaker size). If your existing service panel (column 4) is smaller than the minimum required size of the existing service (column 3), then you will need to install a new upgraded electrical service panel to handle the added electrical load from the proposed Level 2 charger.

The table below is based on CEC 220.83(A), 230.42 and Annex D.

1	2	3	4
Check the appropriate line (✓)	Total Watts Used (from previous page)	Minimum Required Size of Existing 240-Volt Electrical Service Panel (Main Service Breaker Size)	Identify the Size of Your Existing Main Service Breaker (Amps)**
<input type="checkbox"/>	up to 48,000	100 amps	
<input type="checkbox"/>	48,001 to 63,000	125 amps	
<input type="checkbox"/>	63,001 to 78,000	150 amps	
<input type="checkbox"/>	78,001 to 108,000	200 amps	
<input type="checkbox"/>	108,001 to 123,000	225 amps	

****Note that the size of your existing service (column 4) MUST be equal to or larger than the Minimum Required Size (column 3) or a new larger electrical service panel will need to be installed in order to satisfy the electrical load demand of the EV charger.**

STATEMENT OF COMPLIANCE

By my signature, I attest that the information provided is true and accurate.

Job Address: _____

(Print job address)

Signature: _____

(Signature of applicant)

(Date)

In addition to this document, you will also need to provide a copy of the manufacturer's installation literature and specifications for the Level 2 charger you are installing.

Note: This is a voluntary compliance alternative and you may wish to hire a qualified individual or company to perform a thorough evaluation of your electrical service capacity in lieu of this alternative methodology. Use of this electrical load calculation estimate methodology is at the user's risk and carries no implied guarantee of accuracy. Users of this methodology and these forms are advised to seek professional assistance in determining the electrical capacity of a service panel.